



South Carolina Electric & Gas Saluda Project

Reservoir Operations Modeling Using:
Army Corps of Engineers
HEC-ResSim



Afternoon Schedule

- Model Development & Calibration (1st hour)
- Break (20 minutes)
- Future Developments & Potential Results (2nd hour)
- Questions (30 minutes)



Mission Statement

“...establish a baseline of current hydrologic, hydraulic and operational conditions, and aid in analyzing and understanding the potential upstream and downstream effects of potential changes to project operation....”



Model Objectives

- Assess impact of various environmental constraints on project operation
- Assess various project operation schemes for feasibility
- Determine “realistic” plan for future operations



Selected Model – HEC-ResSim

- Publicly available Army Corp of Engineers software (HEC-5)
- Specifically created for reservoir modeling and management
- Flexibility in managing large datasets
- Rule based decisions on daily timesteps
- Application of seasonal rules
- Ability to prioritize rules



US Army Corps
of Engineers




Model Development


- Model Area
 - Includes *Virtual Inflow* from entire watershed
 - Inputs located directly upstream and downstream of Lake Murray
- Input data
 - Reservoir stage/storage data
 - Historic dam releases (Outflow Hydrograph)
 - Historic water levels (Stage data)

Model Development (cont)


- Components
 - Upstream Inflows
 - Lake Murray
 - Downstream Gages
 - Broad & Congaree River Gages




Data Layout - Downstream



Data Layout - Upstream



Data Layout – Lake Murray





Available Data Sources


- Operations Data
 - Generation MWh (SCE&G)
 - Lake Level (USGS)
 - Downstream Flows (USGS)
- NWS – Precipitation data
- USGS – Flow Data
 - Flow Model Hydrology output

Available Data Sources (cont.)

- USGS gages
 - Saluda River at Chappells
 - 1360 sq. miles, 1926-Present
 - Bush River near Prosperity
 - 115 sq. miles, 1990-Present
 - Little River near Silverstreet
 - 230 sq. miles, 1990-Present
 - Saluda River downstream of Lake Murray
 - 2420 sq. miles, 1988-present
 - Saluda River at Columbia
 - 2520 sq. miles, 1925-Present



USGS Gage Locations





Model Process


- Develop model of watershed system
- Calibrate to historical conditions
 - Historical model used to derive system inflows
- Using derived inflows, run simulations using proposed constraints to assess impacts on the Project



Model Process

- Two Methods Tested for Developing Inflow Data:
 - 1) Upstream Gage Rating
 - Utilize available USGS gage data and adjust for ungaged areas
 - 2) Mass Balance
 - Hindcast from outflow and lake level data
historical lake level data

Method 1 - Gage Rating




Method 2 - Mass Balance

Known:

1. Lake Stages
2. Outflow
3. Stage-Volume Relationships

Unknown:

1. Inflow



Fact:

Inflow = Change in Storage (Water Level) + Outflow

Approach:

Back calculate inflow using smoothed lake level data and gaged outflows




Calibration Procedure

1. Develop inflow hydrograph
2. Have model follow stage hydrograph by automatically adjusting discharge
 - Depends on how much flow is entering to decide how much to release
 - Must follow historically observed water levels (stage)
3. Compare calculated stage to observed stage
4. Compare correlation between calculated outflows and observed outflows (USGS gage)
5. Inflow that produces a 'good' fit would be considered calibrated
 - Both Methods were tested with this procedure

Calibration Results


Stage



Discharge


Calibration Results (cont)

Default Plot - Lake Murray, 6:16PM



Calibration Results (cont)

Comparison of Calculated to Recorded Saluda Dam Discharge Rates
(Discharge Calculated to Match Observed Stage)





Calibration Discussion

- Lake level measurements
 - 0.1 feet of variation \sim 2200 cfs on a daily basis. SCE&G notes 0.06 feet is typical “noise” in lake level readings
 - Can result in excessive negative inflows (common problem with hindcast modeling)
 - Lake level data needed to be “smoothed” for mass balance method



Calibration Discussion

- Accuracy of gages downstream of Lake Murray are suspect due to variations in volume
- Gages upstream have limited common period of record (1990-present)
- Low stage periods have poor correlation (result of drawdowns, accuracy of stage storage data)



Calibration Conclusion

- Mass balance method produced best correlation between both lake levels and outflows.
- **Mass balance method produced a highly correlated inflow hydrograph which is now ready for constraint analysis**

Break

- 20 minutes
- Calibration Questions?





Future Developments & Potential Results

- With a calibrated model... (i.e. we know inflow)
 - Evaluate Environmental Constraints
 - Temporal Stage Impacts
 - Temporal Discharge Impacts
 - Determine frequencies that constraints may be violated
- Further Evaluations
 - Downstream flow routing (confluence with Broad R.)
 - Flood Frequency Evaluation



Sample Constraints

- Flow
 - Minimum flow between June 1st and August 1st and should be a minimum of 20,000 cfs for extreme whitewater course
- Stage
 - Maintain Lake Murray at elevation 380.0' year-round



Constraint Requests

- Provide
 - Specific Elevations
 - Specific Flows



Extreme Example Application

- Extreme Flow Releases during Summer Months
- Information Provided
 - Operate during June, July & August
 - Minimum flow of 30,000 cfs
 - Not required on Mondays or Tuesdays

Constraint Setup Example

RES Reservoir Editor

Reservoir: Lake Murray Description: []

Physical Operations Observed Data

Operation Set: Extreme Whitewater Description: Sample Extreme Whitewater Releases

Controlled Release Location: Lake Murray-Controlled Outlet

Rule Name: Seasonal Releases Description: []

Function of: Date Define...

Limit Type: Minimum Interp.: Step

| Date | Release (cfs) |
|-------|---------------|
| 01Jan | 0.0 |
| 01May | 0.0 |
| 01Jun | 30000.0 |
| 01Aug | 30000.0 |
| 01Sep | 0.0 |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

Release (cfs) vs. Month (Jan, Mar, May, Jul, Sep, Nov) graph showing a step function with a peak of 30,000 cfs from June to September.

Hour of Day Multiplier Edit...
 Day of Week Multiplier Edit...
 Rising/Falling Condition Edit...
 Seasonal Variation Edit...

OK Apply Cancel


Day of Week Multiplier

| Day | Multiplier |
|-------|------------|
| Sun | 1.00 |
| Mon | 0.00 |
| Tues | 0.00 |
| Wed | 1.00 |
| Thurs | 1.00 |
| Fri | 1.00 |
| Sat | 1.00 |

OK Cancel

Extreme Example Output

Default Plot - Lake Murray, 11:00PM



Extreme Example Tables


File Edit View

| Ordinate | Date / Time | LAKE MURRA... ELEV-ZONE WHITEWATER0 | LAKE MURRA... ELEV-ZONE WHITEWATER0 | LAKE MURRA... ELEV-ZONE WHITEWATER0 | LAKE MURRA... ELEV WHITEWATER0 | LAKE MURRA... FLOW-IN WHITEWATER0 | LAKE MURRA... FLOW-OUT WHITEWATER0 |
|----------|------------------|---|---|---|--------------------------------------|---|--|
| 239 | 27 May 91 22:... | 360.00 | 357.36 | 346.00 | 357.36 | 2,723 | 2,861 |
| 240 | 28 May 91 22:... | 360.00 | 357.35 | 346.00 | 357.35 | 3,392 | 3,529 |
| 241 | 29 May 91 22:... | 360.00 | 357.35 | 346.00 | 357.35 | 3,497 | 3,635 |
| 242 | 30 May 91 22:... | 360.00 | 357.34 | 346.00 | 357.34 | 4,006 | 4,143 |
| 243 | 31 May 91 22:... | 360.00 | 357.34 | 346.00 | 357.34 | 4,354 | 4,492 |
| 244 | 01 Jun 91 22:... | 360.00 | 357.33 | 346.00 | 357.33 | 4,829 | 4,966 |
| 245 | 02 Jun 91 22:... | 360.00 | 357.31 | 346.00 | 356.23 | 5,285 | 30,000 |
| 246 | 03 Jun 91 22:... | 360.00 | 357.28 | 346.00 | 356.43 | 4,894 | 400 |
| 247 | 04 Jun 91 22:... | 360.00 | 357.26 | 346.00 | 356.59 | 4,044 | 400 |
| 248 | 05 Jun 91 22:... | 360.00 | 357.23 | 346.00 | 355.32 | 1,645 | 30,000 |
| 249 | 06 Jun 91 22:... | 360.00 | 357.21 | 346.00 | 354.08 | 916 | 27,136 |
| 250 | 07 Jun 91 22:... | 360.00 | 357.18 | 346.00 | 352.96 | 1,106 | 23,957 |
| 251 | 08 Jun 91 22:... | 360.00 | 357.16 | 346.00 | 351.98 | 932 | 21,153 |
| 252 | 09 Jun 91 22:... | 360.00 | 357.13 | 346.00 | 351.09 | 721 | 19,006 |
| 253 | 10 Jun 91 22:... | 360.00 | 357.11 | 346.00 | 351.10 | 474 | 400 |
| 254 | 11 Jun 91 22:... | 360.00 | 357.08 | 346.00 | 351.13 | 1,073 | 400 |
| 255 | 12 Jun 91 22:... | 360.00 | 357.06 | 346.00 | 350.37 | 1,618 | 17,257 |
| 256 | 13 Jun 91 22:... | 360.00 | 357.03 | 346.00 | 349.69 | 2,317 | 15,626 |
| 257 | 14 Jun 91 22:... | 360.00 | 357.01 | 346.00 | 349.06 | 2,337 | 14,106 |
| 258 | 15 Jun 91 22:... | 360.00 | 356.98 | 346.00 | 348.49 | 1,985 | 12,720 |
| 259 | 16 Jun 91 22:... | 360.00 | 356.96 | 346.00 | 347.98 | 2,043 | 11,507 |
| 260 | 17 Jun 91 22:... | 360.00 | 356.94 | 346.00 | 348.11 | 2,827 | 400 |
| 261 | 18 Jun 91 22:... | 360.00 | 356.91 | 346.00 | 348.26 | 3,091 | 400 |
| 262 | 19 Jun 91 22:... | 360.00 | 356.89 | 346.00 | 347.83 | 3,261 | 11,223 |
| 263 | 20 Jun 91 22:... | 360.00 | 356.86 | 346.00 | 347.45 | 3,397 | 10,513 |
| 264 | 21 Jun 91 22:... | 360.00 | 356.84 | 346.00 | 347.13 | 4,024 | 9,925 |
| 265 | 22 Jun 91 22:... | 360.00 | 356.81 | 346.00 | 346.80 | 3,150 | 9,310 |
| 266 | 23 Jun 91 22:... | 360.00 | 356.79 | 346.00 | 346.44 | 1,879 | 8,636 |
| 267 | 24 Jun 91 22:... | 360.00 | 356.76 | 346.00 | 346.48 | 1,059 | 400 |
| 268 | 25 Jun 91 22:... | 360.00 | 356.74 | 346.00 | 346.51 | 940 | 400 |

Interpretation of Example Results

- Interpretation of Results
 - Operation following this constraint visually drains the reservoir to a minimum of 346.0'
 - Dry years may not have sufficient inflow to return to Guide Curve
 - 50% of the days have greater than a 1.7' reduction from the Guide Curve

Example Guide Curve Violation Frequency & Magnitude





Constraint Compilation

- Assemble all stage & flow constraints into HEC-ResSim model
- Evaluate various constraints to determine reasonableness



Next Steps

- Develop resource constraints in terms of *FLOW* and *ELEVATION* for model input and analysis
- Run model simulations using constraint inputs
- Determine impact of constraints on:
 - Project Operations
 - Project Generation
 - Downstream flows
 - Flood Frequencies



Questions?



ALTERNATIVE GENERATION EVALUATION

FOR
SALUDA HYDRO

SALUDA HYDRO

SALUDA HYDRO

- TOTAL GENERATION 206 MW

SALUDA HYDRO

- TOTAL GENERATION 206 MW
- UNITS 1-4 34 MW EA.

SALUDA HYDRO

- TOTAL GENERATION 206 MW
- UNITS 1-4 34 MW EA.
- UNIT 5 70 MW

SALUDA HYDRO

- TOTAL GENERATION 206 MW
- UNITS 1-4 34 MW EA.
- UNIT 5 70 MW
- START TIME <15 MIN.

SALUDA HYDRO

- TOTAL GENERATION 206 MW
- UNITS 1-4 34 MW EA.
- UNIT 5 70 MW
- START TIME <15 MIN.
- RELIABILITY >95%

SALUDA HYDRO

- TOTAL GENERATION 206 MW
- UNITS 1-4 34 MW EA.
- UNIT 5 70 MW
- START TIME <15 MIN.
- RELIABILITY >95%
- QUICK START RESERVE 206 MW

SALUDA HYDRO

- TOTAL GENERATION 206 MW
- UNITS 1-4 34 MW EA.
- UNIT 5 70 MW
- START TIME <15 MIN.
- RELIABILITY >95%
- QUICK START RESERVE 206 MW
- BLACKSTART VC SUMMER

SALUDA HYDRO

- TOTAL GENERATION 206 MW
- UNITS 1-4 34 MW EA.
- UNIT 5 70MW
- START TIME <15 MIN.
- RELIABILITY >95%
- QUICK START RESERVE 206 MW
- BLACKSTART VC SUMMER
- LAKE LEVEL MANAGEMENT

**ALTERNATIVE GENERATION
TO
SALUDA HYDRO**

EVALUATION OF VIABLE OPTIONS

EVALUATION CONSIDERATIONS

EVALUATION CONSIDERATIONS

- **ELECTRIC GENERATING EQUIPMENT**

EVALUATION CONSIDERATIONS

- **ELECTRIC GENERATING EQUIPMENT**
- **PLANT SITING**

EVALUATION CONSIDERATIONS

- ELECTRIC GENERATING EQUIPMENT
- PLANT SITING
- CAPITAL AND O&M DOLLARS

EQUIPMENT EVALUATION

EQUIPMENT EVALUATION

- CAPACITY 200 MW

EQUIPMENT EVALUATION

- CAPACITY 200 MW
- START TIME <15 MIN.

EQUIPMENT EVALUATION

- CAPACITY 200 MW
- START TIME <15 MIN.
- EFFICIENCY

EQUIPMENT EVALUATION

- CAPACITY 200 MW
- START TIME <15 MIN.
- EFFICIENCY
- RELIABILITY

EQUIPMENT EVALUATION

- CAPACITY 200 MW
- START TIME <15 MIN.
- EFFICIENCY
- RELIABILITY
- PROVEN TECHNOLOGY

EQUIPMENT ALTERNATIVES

EQUIPMENT ALTERNATIVES

- **DIESEL GENERATORS**

EQUIPMENT ALTERNATIVES

- DIESEL GENERATORS
- GAS TURBINES (AERO DERIVED)

DIESEL GENERATORS

DIESEL GENERATORS

- SIZE 2 – 2 1/2 MW

DIESEL GENERATORS

- SIZE 2 – 2 1/2 MW
- GENSET

DIESEL GENERATORS

- SIZE 2 – 2 1/2 MW
- GENSET
- 80-100 UNITS

DIESEL GENERATORS

- SIZE 2 – 2 1/2 MW
- GENSET
- 83-100 UNITS
- START TIME 10 MIN.


DIESEL GENERATORS


- SIZE 2 – 2 1/2 MW
- GENSET
- 83-100 UNITS
- START TIME 10 MIN.
- EFFICIENCY 37%

DIESEL GENERATORS

- SIZE 2 – 2 1/2 MW
- GENSET
- 83-100 UNITS
- START TIME 10 MIN.
- EFFICIENCY 37%
- RELIABILITY 90%

DIESEL GENSET





PLAN "SAFETY" SHEET EVERY JOB

| | | |
|-----|-------------|------|
| NO. | DESCRIPTION | DATE |
| 1 | DESIGNED BY | |
| 2 | CHECKED BY | |
| 3 | APPROVED BY | |
| 4 | DATE | |

Departmental knowledge and approval of all work

GAS TURBINES(AERO DERIVED)

GAS TURBINES(AERO DERIVED)

- **SIZE**

50 MW

GAS TURBINES(AERO DERIVED)

- SIZE 50 MW
- GENERAL ELECTRIC LM6000

GAS TURBINES(AERO DERIVED)

- SIZE 50 MW
- GENERAL ELECTRIC LM6000
- 4 UNITS

GAS TURBINES(AERO DERIVED)

- SIZE 50 MW
- GENERAL ELECTRIC LM6000
- 4 UNITS
- START TIME 10 MIN.

GAS TURBINES(AERO DERIVED)

- SIZE 50 MW
- GENERAL ELECTRIC LM6000
- 4 UNITS
- START TIME 10 MIN.
- EFFICIENCY 40%

GAS TURBINES(AERO DERIVED)

- SIZE 50 MW
- GENERAL ELECTRIC LM6000
- 4 UNITS
- START TIME 10 MIN.
- EFFICIENCY 40%
- RELIABILITY 90%





PLANT SITING EVALUATION

PLANT SITING EVALUATION

- PERMITTING

PLANT SITING EVALUATION

- PERMITTING
- WATER AVAILABILITY

PLANT SITING EVALUATION

- PERMITTING
- WATER AVAILABILITY
- INTERCONNECTIONS

PLANT SITING EVALUATION

- PERMITTING
- WATER AVAILABILITY
- INTERCONNECTIONS
- PLANT LAYOUT /CONSTRUCTABILITY

PLANT SITING EVALUATION

- PERMITTING
- WATER AVAILABILITY
- INTERCONNECTIONS
- PLANT LAYOUT /CONSTRUCTABILITY
- LAND AVAILABILITY

PLANT SITING EVALUATION

- PERMITTING
- WATER AVAILABILITY
- INTERCONNECTIONS
- PLANT LAYOUT /CONSTRUCTABILITY
- LAND AVAILABILITY
- PSC APPROVAL

PERMITTING

PERMITTING

- AIR EMISSIONS

PERMITTING

- AIR EMISSIONS
- WATER INTAKE

PERMITTING

- AIR EMISSIONS
- WATER INTAKE
- WATER DISCHARGE

PERMITTING

- AIR EMISSIONS
- WATER INTAKE
- WATER DISCHARGE
- STORM WATER CONTROL

PERMITTING

- AIR EMISSIONS
- WATER INTAKE
- WATER DISCHARGE
- STORM WATER CONTROL
- WETLANDS

PERMITTING

- AIR EMISSIONS
- WATER INTAKE
- WATER DISCHARGE
- STORM WATER CONTROL
- WETLANDS
- COUNTY REGULATIONS

PERMITTING

- AIR EMISSIONS
- WATER INTAKE
- WATER DISCHARGE
- STORM WATER CONTROL
- WETLANDS
- COUNTY REGULATIONS
- SCHEDULE IMPACT 1-2 YEARS

DOLLARS EVALUATION

DOLLARS EVALUATION

- CAPITAL COST

DOLLARS EVALUATION

- CAPITAL COST
- LIFE CYCLE COST 30 YRS

COST OF:

COST OF:

- LAND

COST OF:

- LAND
- PERMITTING

COST OF:

- LAND
- PERMITTING
- GENERATING EQUIPMENT

COST OF:

- LAND
- PERMITTING
- GENERATING EQUIPMENT
- BALANCE OF PLANT

COST OF:

- LAND
- PERMITTING
- GENERATING EQUIPMENT
- BALANCE OF PLANT
- ENGINEERING

COST OF:

- LAND
- PERMITTING
- GENERATING EQUIPMENT
- BALANCE OF PLANT
- ENGINEERING
- CONSTRUCTION

COST OF:

- LAND
- PERMITTING
- GENERATING EQUIPMENT
- BALANCE OF PLANT
- ENGINEERING
- CONSTRUCTION
- START-UP

COST OF:

- LAND
- PERMITTING
- GENERATING EQUIPMENT
- BALANCE OF PLANT
- ENGINEERING
- CONSTRUCTION
- START-UP
- PROJECT MANAGEMENT

PARAMETERS / ASSUMPTIONS

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE
- +25% / -10% ACCURACY

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE
- +25% / -10% ACCURACY
- 2006 DOLLARS FOR CAPITAL \$
- 2010 DOLLARS FOR LIFE CYCLE \$

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE
- +25% / -10% ACCURACY
- 2006 DOLLARS FOR CAPITAL \$
- 2010 DOLLARS FOR LIFE CYCLE \$
- ESCALATION EXCLUDED

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE
- +25% / -10% ACCURACY
- 2006 DOLLARS FOR CAPITAL \$
- 2010 DOLLARS FOR LIFE CYCLE \$
- ESCALATION EXCLUDED
- COST OF MONEY EXCLUDED

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE
- +25% / -10% ACCURACY
- 2006 DOLLARS FOR CAPITAL \$
- 2010 DOLLARS FOR LIFE CYCLE \$
- ESCALATION EXCLUDED
- COST OF MONEY EXCLUDED
- PROVEN GENERATION TECHNOLOGY

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE
- +25% / -10% ACCURACY
- 2006 DOLLARS FOR CAPITAL \$
- 2010 DOLLARS FOR LIFE CYCLE \$
- ESCALATION EXCLUDED
- COST OF MONEY EXCLUDED
- PROVEN GENERATION TECHNOLOGY
- NEW PLANT SITE

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE
- +25% / -10% ACCURACY
- 2006 DOLLARS FOR CAPITAL \$
- 2010 DOLLARS FOR LIFE CYCLE \$
- ESCALATION EXCLUDED
- COST OF MONEY EXCLUDED
- PROVEN GENERATION TECHNOLOGY
- NEW PLANT SITE
- NATURAL GAS AVAILABLE

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE
- +25% / -10% ACCURACY
- 2006 DOLLARS FOR CAPITAL \$
- 2010 DOLLARS FOR LIFE CYCLE \$
- ESCALATION EXCLUDED
- COST OF MONEY EXCLUDED
- PROVEN GENERATION TECHNOLOGY
- NEW PLANT SITE
- NATURAL GAS AVAILABLE
- TRANSMISSION CONNECTION AVAILABLE

PARAMETERS / ASSUMPTIONS

- ORDER OF MAGNITUDE ESTIMATE
- +25% / -10% ACCURACY
- 2006 DOLLARS FOR CAPITAL \$
- 2010 DOLLARS FOR LIFE CYCLE \$
- ESCALATION EXCLUDED
- COST OF MONEY EXCLUDED
- PROVEN GENERATION TECHNOLOGY
- NEW PLANT SITE
- NATURAL GAS AVAILABLE
- TRANSMISSION CONNECTION AVAILABLE
- WATER AVAILABLE

CAPTITAL COST DIESEL GEN

| | |
|--------------------|--------------|
| ● LAND | \$100,000 |
| ● PERMITTING | \$160,000 |
| ● EQUIPMENT | \$40,500,000 |
| ● BALANCE OF PLANT | \$38,000,000 |
| ● ENGINEERING | \$500,000 |
| ● CONSTRUCTION | \$7,000,000 |
| ● START-UP | \$250,000 |
| ● PROJECT MGMT | \$250,000 |
| ● TOTAL | \$86,850,000 |

CAPITAL COST GAS TURBINES

| | |
|--------------------|--------------|
| ● LAND | \$100,000 |
| ● PERMITTING | \$160,000 |
| ● EQUIPMENT | \$58,800,000 |
| ● BALANCE OF PLANT | \$18,780,000 |
| ● ENGINEERING | \$600,000 |
| ● CONSTRUCTION | \$11,400,000 |
| ● START-UP | \$200,000 |
| ● PROJECT MGMT | \$300,000 |
| ● TOTAL | \$90,390,000 |

CAPITAL COST SALUDA HYDRO

| | |
|--------------------|---------------|
| ● LAND | NA |
| ● RE-LICENSING | <\$12 MILLION |
| ● EQUIPMENT | \$20,000,000 |
| ● BALANCE OF PLANT | In- above |
| ● ENGINEERING | In-above |
| ● CONSTRUCTION | In-above |
| ● START-UP | In-above |
| ● PROJECT MGMT | In-above |
| ● TOTAL | \$32,000,000 |

LIFE CYCLE COSTS 30 YEARS

(includes capital, O&M, fuel)

- SALUDA \$174,000,000
- GAS TURBINES \$508,230,000
- DIESEL GEN'S \$705,000,000

SALUDA ADVANTAGES

SALUDA ADVANTAGES

- LOWER LIFE CYCLE COST

SALUDA ADVANTAGES

- LOWER LIFE CYCLE COST
- BETTER RELIABILITY

SALUDA ADVANTAGES

- LOWER LIFE CYCLE COST
- BETTER RELIABILITY
- NO AIR EMISSIONS

SALUDA ADVANTAGES

- LOWER LIFE CYCLE COST
- BETTER RELIABILITY
- NO AIR EMISSIONS
- NO NEW PLANT SITING IMPACT

SALUDA ADVANTAGES

- LOWER LIFE CYCLE COST
- BETTER RELIABILITY
- NO AIR EMISSIONS
- NO NEW PLANT SITING IMPACT
- AVAILABLE QUICK START RESERVE

SALUDA ADVANTAGES

- LOWER LIFE CYCLE COST
- BETTER RELIABILITY
- NO AIR EMISSIONS
- NO NEW PLANT SITING IMPACT
- AVAILABLE QUICK START RESERVE
- VCS BLACKSTART CAPABILITY

ALT GENERATION IMPACTS

ALT GENERATION IMPACTS

- **HIGHER RATES FOR ELECTRICITY**

ALT GENERATION IMPACTS

- HIGHER RATES FOR ELECTRICITY
- HIGHER EMISSIONS

ALT GENERATION IMPACTS

- HIGHER RATES FOR ELECTRICITY
- HIGHER EMISSIONS
- LAND USE

QUESTIONS?



South Carolina Electric & Gas Saluda Project

Reservoir Modeling



Model Objectives

- What are the objectives of the modeling work?
 - Reservoir Model
 - Watershed Model
 - Water Quality Model
 - Generation Model
 - System Model
 - Other



Model Objectives

- Hydrologic Model
- Hydraulic Model
- Economic Model
- Water Quality Model

- Combination of all?



Model Objectives

- Suggested objectives from 12/6 Operations Group Meeting
 - Lake levels
 - LSR or Minimum Flows
 - Inflows
 - Generation
 - Storage
 - Graphic Ability
 - Interactive Front End



Mission Statement

“...establish a baseline of current hydrologic, hydraulic and operational conditions, and aid in analyzing and understanding the potential upstream and downstream effects of potential changes to project operation....”



System Modeling

- Potential new model options
 - HEC-5
 - OASIS
 - CHEOPS
 - *MIKE Basins*
 - *WMS*
 - Decision Support Programs

HEC-5



- Designed to simulate a sequential operation of a reservoir channel system
- Public domain software
- Major focus of model
 - Reservoir operations
 - Flood Control
 - Optimization of Water Supply and Hydropower operations
 - Flood Damage and reservoir economics



OASIS

- Routes water through a **water resource system**
- Extremely flexible
- Purchased Software
- Can account for both human and physical constraints on the reservoir system.
- Allows for assessment of management options, supply options, alterations due to biologic requirements or other sociologic driven demands.




OASIS

- Operates using Constraints and Goals for all decisions
- Ability to interface with a wide variety of other models.
- Can run several models simultaneously within the OASIS shell.
- Graphical Interfaces

Zoom 60 %




Kansas River Basin Simulation Model



NODES


ARCS



Select items for editing

 Output CURRENT

System Storage



— Total Milford Storage

— Total Perry Storage

— Total Tuttle Creek Storage

— Total Clinton Storage




CHEOPS

- Operations and Planning Program
- Models reservoir systems
- Private domain software
- Focuses on hydroelectric optimization
- Has Graphical and Tabular Outputs
- Potential for Long Run Time

Base Case New Runner (Normal 1983)

Nantahala Reservoir Operational Details
for 1983 Hydrology, Scenario 'Base Case New Runner'





Existing Models

- SCE&G Flow Forecast Model
 - Currently used to model what-if scenarios for project operations.
 - Model is calibrated to system, updated as required
 - Run daily – incorporates NWS and USGS data.
 - Encompasses entire Saluda Basin
 - Rainfall/Runoff Relationship
 - Reservoir levels
 - Inflows/Outflows
 - Minimum flows
 - Meets almost all criteria noted in minutes from 12/6 group meeting



Existing Models

- RMS 4 – Downstream water quality (DO and Temp) and simulated fish growth
- W2 model
 - Assessed water quality parameters of reservoir.
 - Phosphorous
 - DO
 - Thermal Stratification



Conclusion

- Most of the noted objectives are met with existing models
- Any additional model objectives need to be identified
- Can existing models be modified to meet all required objectives?



Data Sources

- SCE&G Operations Data
 - Generation
 - Lake Level
 - Tailwater
 - Downstream flows
- NWS – Precipitation data
- USGS – Flow Data
 - Flow Model Hydrology output



Data Sources

- Other Resources?



Output Requirements

- Water Levels
- Generation Impacts
- Downstream levels
- Economics



Model Methodology

- Use typical year
- Hold inflows constant to assess impact on changes in operation on lake levels

Saluda Hydro Operations


*William R. Argentieri, P.E.
Fossil & Hydro Technical Services*



Hydropower Basics


- *Hydroelectric plants convert potential energy of water into kinetic energy to drive a generator.*
- *Water flows from “headwater” elevation to “tailwater” elevation through a hydraulic turbine, which is connected to a generator.*

HYDRO DAM




Saluda Hydro Basic Facts

- *Saluda Hydroelectric Project was built between 1927 and 1930.*
- *Saluda Hydro originally had four turbine-generator units installed.*
- *A fifth unit was added in 1969 - 1971.*
- *Generation capacity is 206 MW*
- *Hydraulic capacity is 18,000 CFS (8 million GPM!)*




- *Drainage Basin Area 2,420 sq. mi.*
- *Reservoir surface area 50,000 acres at elev. 360.0 SPD.*
- *Reservoir capacity 1,600,000 ac-ft at elev. 360.0 SPD.*



Units 1 - 4

- *Units 1 – 4 turbines are Francis reaction type, built by S. Morgan Smith Co., and develop over 55,000 HP each at 138.5 RPM. Design head is 180 feet.*
- *Units 1 - 4 generators are Westinghouse machines operating at 13,800 VAC.*
- *Units 1, 2 & 4 generators are rated at 32.5 MW. Unit 3 was rewound in 1966 and is now rated at 42.3 MW.*




Unit 1 – 4 Turbine Runner (Bottom View)



Francis Turbine Runner Similar to Saluda 1 - 4

Water Flow in a Francis Turbine

Left: relative to turbine blades Right: true water path



Unit 5

- *Unit 5 turbine is also a Francis reaction type, built by Baldwin-Lima-Hamilton and developing 98,300 HP at 128.6 RPM.*
- *Design head is 156 feet.*
- *Unit 5 generator is a General Electric machine rated at 75 MW at 13,800 VAC.*

Intake Towers

- *Towers 1 – 4 are 30 feet in diameter and 223 feet tall.*
- *Each tower has two 9 ft. by 14 ft. Broome roller gates with sills at bottom of reservoir - elevation 160 ft. Saluda Plant Datum (SPD).*
- *Gates are operated by electric hoists in brick machine houses atop each tower.*

Intake Towers

- *Tower 5 is 60 feet in diameter and 223 feet tall.*
- *It was designed to supply two future units similar to the original four.*
- *It now supplies Unit 5, which is about twice as large as the original units.*
- *Tower 5 has six 10 ft. by 10 ft. Broome roller gates with sills at elevation 271.67 ft. SPD.*

Emergency Spillway

- *Emergency spillway is used to release water from reservoir in excess of what can be passed through the plant and stored in reservoir.*
- *Only used to prevent uncontrolled reservoir rise which threatens to overtop the dam.*
- *Spillway is tested each year by opening one gate fully, and raising others one foot each.*
- *Spillway is NOT the original Saluda River channel. It is a man-made channel.*


Emergency Spillway

- *Four gates 37.5 ft W x 25 ft H – original*
- *Two gates 46.5 ft W x 32 ft H – added 1946*
- *Each of the six spillway gates has its own hoist.*
- *Primary power for gate hoists is overhead electric.*
- *Backup generator is located near spillway.*
- *Gates can be operated using compressed air if electric hoist motors fail.*

Spillway Hydraulic Capacity

- *Flow through the spillway depends on number of gates opened, how far the gates are raised, and the reservoir elevation.*
- *Spillway hydraulic capacity with all gates fully open and reservoir at el. 360 SPD is about 90,000 CFS (five times powerhouse hydraulic capacity).*
- *Maximum spillway hydraulic capacity with all gates fully open and reservoir at el. 377 SPD is about 197,000 CFS.*

Spillway Rating Curve - All Gates Fully Open



Emergency Spillway

- *Spillway has been operated four times during floods – in 1936, 1964, 1965, and 1969.*
- *Installation of Unit 5 increased ability to pass flood flows through powerhouse, reducing frequency of spillway operation.*
- *Spillway operation to pass floods has not been required since 1969.*

Project Operation

- *Saluda Hydro is normally operated as a reserve plant, to quickly replace other system generation which is offline for some reason.*
- *Saluda Hydro can respond quickly to provide generation and keep the system stable.*
- *Occasionally Saluda Hydro is used to augment other system generation at times of extremely high demand.*
- *Saluda also has “black start” capability to get system back up after catastrophic outage.*


Project Operations – Reservoir Level

- *Project License sets a minimum reservoir elevation of 345 ft. SPD, and a maximum reservoir elevation of 360 ft. SPD.*
- *SCE&G normally operates the reservoir in the range of 350 to 358 ft. SPD.*
- *Reservoir is occasionally drawn down to near el. 345 ft. SPD for vegetation control or other maintenance work.*

Project Operations – Reservoir Level

- *SCE&G sets target reservoir elevations for each month of the year, to allow for seasonal inflow variations.*
- *These target elevations may vary from year to year, depending on inflow available, maintenance activities, unit availability, etc.*
- *It is important to remember that each year is different – there is no “normal year”.*
- *There is no one “Rule Curve” for reservoir operation.*

Example Target Elevation & Month End Elevation



Historical Floods

- *August 1928: 58,200 CFS (During project construction)*
- *March 1929: 53,600 CFS (During project construction)*
- ***October 1929: 67,000 CFS (During project construction, flood of record for basin)***
- ***April 1936: 61,600 CFS (Highest recorded lake level 361.5 SPD resulted) – 4 Gates Opened***
- *April 1964: 38,800 CFS – 2 Gates Opened*
- *June 1965: 53,200 CFS – 4 Gates Opened*
- *April 1969: 35,700 CFS – 2 Gates Opened*



Powerhouse Foundation During Flood, October 1929



Powerhouse Foundation After Flood, October 1929

Inflow Design Flood (IDF)

- *The IDF is the largest hypothetical flood which can be safely accommodated by the project.*
- *The IDF for Saluda is the Probable Maximum Flood (PMF) - the largest flood determined to be probable in the basin.*
- *The PMF results from a hypothetical storm of optimum size, shape, and orientation to produce maximum runoff in the drainage basin.*
- *The PMF inflow for Saluda Hydro is 572,300 CFS – almost 10 times the flood of record.*

Inflow Design Flood (IDF)

- *Dam has been modified twice to accommodate updated estimates of the PMF.*
 - *1940s – Dam crest raised 3 feet to el. 375.0 SPD, two spillway gates added.*
 - *1990 – Latest PFM lake level would be 375.9 SPD. Sheet pile freeboard wall added to dam crest – top of wall el. 377.0 SPD.*
- *Flow Forecast Model was developed to predict reservoir level during floods.*




Sheet Pile Freeboard Wall Construction - 1990

Project Operation – Flow Forecast Model

- *Flow Forecasting Model (FFM) is a computer based model used to predict inflow and reservoir rise from storm events in the basin.*
- *The FFM uses NWS forecasts and USGS rain and flow gage data as input to a hydrologic/hydraulic model which predicts runoff and stream flow.*
- *SCE&G uses the FFM to decide how much to lower the reservoir in advance of a large storm system, how much to generate to maintain the lake level, and whether spillway operation is required.*

- Available Historic Data
 - First Date: 01/01/93 01:00
 - Last Date: 12/01/05 07:00
 - Last Acquired: 12/01/05 08:15
 - Status: No Errors
- Database Configuration
- Precipitation
 - QPF Day 1: 12/01/2005
- Model Inputs
- Buzzards Roost Dam
 - Inflow: 3335 cfs
 - Outflow: 674 cfs
 - Pool Elev: 436.87 ft msl
- Model Input: Turbine Flow
- Model Input: Gate Openings
- Saluda Dam
 - Inflow: 4445 cfs
 - Outflow: 602 cfs
 - Pool Elev: 354.64 ft msl
- Model Input: Turbine Flow
- Model Input: Gate Openings
- Other Locations
 - Parr Shoals: 258.04 ft msl
 - Broad R @ Alston: 1820 cfs
 - Savannah R @ Augusta: 9830 cfs



Lake Murray near Columbia, SC (02168500) - STAGE View...


FFM Screen – Current Conditions

Precipitation (QPF) | Buzzards Roost Dam | Saluda Dam

Forecast Start Date-time (GMT): 06/13/05 00:00

Specify Precipitation Forecasts by Gage

| Station Name | Day 1 | Day 2 | Day 3 | Day 4 | Day 5 |
|--------------|-------|-------|-------|-------|-------|
| Liberty | 0 | 0 | 0 | 0 | 0 |
| Gmville | 0 | 0 | 0 | 0 | 0 |
| Belton | 0 | 0 | 0 | 0 | 0 |
| GrayCrt | 0 | 0 | 0 | 0 | 0 |
| Greenwd | 0 | 0 | 0 | 0 | 0 |
| Buzzards | 0 | 0 | 0 | 0 | 0 |
| Newberry | 0 | 0 | 0 | 0 | 0 |
| LkMurray | 0 | 0 | 0 | 0 | 0 |
| Batesbrg | 0 | 0 | 0 | 0 | 0 |
| Saluda | 0 | 0 | 0 | 0 | 0 |
| Edgefld | 0 | 0 | 0 | 0 | 0 |



Valid from 12/02/05 12:00 GMT to 12/03/05 12:00 GMT

Specify Basin-Average Precipitation Forecasts

| Station Name | Day 1 | Day 2 | Day 3 | Day 4 | Day 5 |
|--------------|-------|-------|-------|-------|-------|
| Basin Avg | 0 | 0 | 0 | 0 | 0 |

QPF Forecast to Display

Day 1
 Day 2
 Day 3
 Days 4-5

Desired View

GIS Map
 Bitmap Image

Configuration Parameters

Simulation Start Date: 06/13/05

FFM Screen – NWS Precipitation Forecast

Is Dam Failure Assumed?

Pool elevation at failure:

Date-time of failure:

Lake Murray pond elevation at start of simulation (ft msl):

Current Pool Level (ft msl) as of 12/01/05 06:00: 354.64

Normal Pool Level (ft msl): 358.00

Maximum Operating Pool (ft msl): 360.00

Configuration Parameters

Load... Save As... Simulation Start Date: Reset Dates

OK Cancel

FFM Screen – Model Input Screen - General

| Date-Time | Flow (cfs) |
|------------------|------------|
| 06/13/2005 00:00 | 2700 |
| 06/13/2005 04:00 | 2700 |
| 06/13/2005 08:00 | 2700 |
| 06/13/2005 12:00 | 2700 |
| 06/13/2005 16:00 | 2700 |
| 06/13/2005 20:00 | 2700 |
| 06/14/2005 00:00 | 2700 |
| 06/14/2005 04:00 | 2700 |
| 06/14/2005 08:00 | 2700 |
| 06/14/2005 12:00 | 2700 |
| 06/14/2005 16:00 | 2700 |
| 06/14/2005 20:00 | 2700 |
| 06/15/2005 00:00 | 2700 |
| 06/15/2005 04:00 | 2700 |
| 06/15/2005 08:00 | 2700 |
| 06/15/2005 12:00 | 2700 |
| 06/15/2005 16:00 | 2700 |
| 06/15/2005 20:00 | 2700 |
| 06/16/2005 00:00 | 2700 |
| 06/16/2005 04:00 | 2700 |
| 06/16/2005 08:00 | 2700 |
| 06/16/2005 12:00 | 2700 |
| 06/16/2005 16:00 | 2700 |
| 06/16/2005 20:00 | 2700 |
| 06/17/2005 00:00 | 2700 |
| 06/17/2005 04:00 | 2700 |
| 06/17/2005 08:00 | 2700 |
| 06/17/2005 12:00 | 2700 |
| 06/17/2005 16:00 | 2700 |

Tabular
Graphical

General | Turbines | Gates

Configuration Parameters

Load... Save As... Simulation Start Date: 06/13/05 Reset Dates

OK Cancel

FFM Screen – Model Input Screen - Turbines

| Date-Time | Gate 1 (ft) (Ogee) | Gate 2 (ft) (Ogee) | Gate 3 (ft) (Ogee) | Gate 4 (ft) (Ogee) | Gate 5 (ft) (Flat) | Gate 6 (ft) (Flat) |
|------------------|--------------------|--------------------|--------------------|--------------------|--------------------|--------------------|
| 06/13/2005 00:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/13/2005 04:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/13/2005 08:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/13/2005 12:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/13/2005 16:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/13/2005 20:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/14/2005 00:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/14/2005 04:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/14/2005 08:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/14/2005 12:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/14/2005 16:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/14/2005 20:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/15/2005 00:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/15/2005 04:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/15/2005 08:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/15/2005 12:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/15/2005 16:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/15/2005 20:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/16/2005 00:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/16/2005 04:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/16/2005 08:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/16/2005 12:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/16/2005 16:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/16/2005 20:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/17/2005 00:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/17/2005 04:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/17/2005 08:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/17/2005 12:00 | 0 | 0 | 0 | 0 | 0 | 0 |
| 06/17/2005 16:00 | 0 | 0 | 0 | 0 | 0 | 0 |

Tabular
Graphical

General | Turbines | Gates

Configuration Parameters

Simulation Start Date:

FFM Screen – Model Input Screen - Gates

Project Operation – Flow Forecast Model

- *The FFM can model different “what if” scenarios – various combinations of powerhouse and spillway operations can be input to determine effect on reservoir level.*
- *The FFM models conditions at Buzzards Roost (Lake Greenwood), as well as Saluda Hydro.*
- *FFM database is updated daily from USGS and NWS servers.*

Project Operation - Storms

- *Floods cause high tailwater conditions at the Saluda powerhouse, reducing generating capability due to lower effective head.*
- *High tailwater can also flood portions of the powerhouse if precautions are not taken – stop logs at work bay door, seals at ventilation louvers.*
- *Powerhouse had to be sealed during the 1965 flood – tailwater rose to almost 199 ft. SPD.*

Project Operation - Restrictions

- *Informal agreement in place with SCDHEC to maintain 180 CFS minimum flow in lower Saluda River.*
- *McMeekin Station discharges cooling water to Unit 2.*
- *McMeekin NPDES Permit requires that Saluda Hydro discharge 2,500 CFS when Unit 2 is operated, or when cooling water is bypassed to tailrace.*

Project Operation – Restrictions

- *Unit 5 operations are often restricted during summer due to fish schooling around intake tower – hydroacoustic system detects presence of fish and displays in System Control Room.*



McMeekin Cooling Water Bypass – June 2005

Project Operation – DO Issues

- *During late summer and fall, dissolved oxygen in reservoir becomes depleted below about 75 feet depth.*
- *SCE&G has installed turbine vents and hub baffles to enhance air entrainment into turbine discharges.*
- *Venting efficiency varies with load on unit – generally better venting occurs in middle third of load range.*

Project Operation – DO Issues

- *SCE&G uses Look Up Tables (LUTs) to dispatch units according to reservoir DO levels and venting capability of each unit.*
- *Attempt to optimize operations to mitigate DO impact to lower Saluda River.*
- *This usually results in having to spread load over several units during low DO season.*

Project Maintenance - Powerhouse

- *Normal preventive maintenance work is performed constantly.*
- *Periodic maintenance requiring brief unit outage is performed as required during the year.*
- *Major maintenance requiring prolonged unit outage or dewatering of a unit is scheduled for low demand time of year, if possible.*

Project Maintenance - Powerhouse

- *Dewatering of a unit requires closing butterfly valve for Units 1 – 4, or closing head gate at tower for Unit 5.*
- *Dewatering of a penstock requires closing head gate at tower.*
- *Dewatering penstock and scroll case can take as long as a week, depending on how well gates seal.*

Project Maintenance - Dam

- *Lake is occasionally drawn down to about el. 345 SPD for maintenance of dam and appurtenant structures, or for control of vegetation in reservoir.*
- *Repair of the upstream riprap armor planned for winter 2006 will require reservoir draw down to about el. 348 SPD.*

Public Safety Plan

- *Submitted as part of the license application.*
- *Provides locations of operational sirens, warning signs, strobe lights, etc.*
- *On the lake we have warning signs only at the public access locations.*
- *On the river, we have sirens, warning signs, and strobe lights at two locations, Mill Race Rapids at the Zoo and Hope Ferry Landing/ Saluda Shoals Park.*

-WARNING-
HORN SIGNAL and
FLASHING LIGHTS
INDICATE RISING WATER
-CAUTION-
ABSENCE of HORN SIGNAL or
FLASHING LIGHTS **DO NOT** ASSURE
CONSTANT WATER LEVEL



Dam Surveillance Program

- *SCE&G performs monthly dam surveillance in accordance with FERC regulations.*
- *Both original dam and backup dam are instrumented to monitor water level and pressure, seepage, and deformation.*
- *SCE&G technicians collect instrument data and inspect dam at least monthly, more often if unusual conditions present.*
- *Dam is surveyed semi-annually.*
- *Surveillance Report filed with FERC annually.*

Emergency Action Plan (EAP)

- *SCE&G maintains an Emergency Action Plan (EAP) detailing response to potential or actual failure of dam.*
- *EAP contains procedures used to notify local, state, and federal officials in event of dam related emergency and inundation maps showing the flood area during the Probable Maximum Precipitation and Sunny Day failure.*

Emergency Action Plan (EAP)

- *During the dam remediation we installed 10 early warning sirens that are still active today. We also published an Emergency Information Brochure to provide guidance to the public should these sirens need to be activated. This brochure is mailed to those in the inundation zone and can be found on the SCE&G website.*
- *Purpose is to allow coordination of downstream notification/evacuation if required.*

Emergency Action Plan (EAP)

- *EAP is updated annually with current contact information for response agencies.*
- *EAP tabletop and functional exercises are conducted every 5 years to test communications channels and procedures.*
- *Plant personnel attend annual EAP training session on procedures.*

Questions?